



NEENAH R-3067-V CASTING (R-3067-VB AT LOW POINTS) OR EQUAL

MINIMUM OF 2", MAXIMUM OF 12" OF HDPE ADJUSTMENT RINGS. WOVEN FILTER FABRIC SHALL THEN BE WRAPPED AROUND HDPE RINGS. CONCRETE COLLAR SHALL BE PLACED AROUND FILTER FABRIC.

6" PRECAST REINFORCED CONCRETE SLAB.

TOP OF BARREL SECTION BELOW TOP SLAB TO HAVE FLAT TOP EDGE SEALED WITH 2 BEADS OF RAMNEK OR EQUAL.

PRECAST CONCRETE SECTION
 DOGHOUSES SHALL BE GROUTED ON BOTH THE OUTSIDE AND INSIDE.

MANHOLE STEPS, NEENAH R1981J OR EQUAL, 15" O.C., ALUMINUM STEPS APPROVED.

STORM SEWER SHALL BE RCP.
 NO BLOCK STRUCTURES ARE ALLOWED.



STANDARD DETAILS
CATCHBASIN MANHOLE WITH SUMP

COTTAGE GROVE, MINNESOTA

LAST REVISION:
 JAN 2014

PLATE NO.
 STO-6